



**PAVUS, a.s.**  
AUTHORIZED BODY 216  
NOTIFIED BODY 1391  
ACCREDITED CERTIFICATION BODY FOR  
PRODUCTS N° 3041

Branch: FIRE TESTING LABORATORY  
VESELÍ NAD LUŽNICÍ  
Čtvrť J. Hybeše 879  
CZ 391 81 Veselí nad Lužnicí  
Czech Republic

Address:  
Prosecká 412/74, 190 00 Praha 9 – Prosek  
Tel.: 286 019 587 Fax: 286 019 590  
E-mail: mail@pavus.cz, http://www.pavus.cz

Phone: +420 381 477 418  
Fax: +420 381 477 419  
Mail to: veseli@pavus.cz

## CLASSIFICATION REPORT ON THE EXTERNAL FIRE EXPOSURE OF ROOFS

The object of  
classification :

*Roofs and roof coverings  
in accordance with ČSN EN 13501-5+A1:2010, clause 8.3 and 9*

Issue number:

**PK5-03-11-006-A-0**

Product name and type:

*Waterproof membrane FATRAFOL 810/V*

Sponsor:

*Fatra, a.s.  
tř. Tomáše Bati 1541  
763 61 Napajedla*

Issuing organization:

*PAVUS, a.s.  
Authorized Body 216  
Notified Body 1391  
Accredited certification body for products N° 3041  
- Accreditation issued by Czech Accreditation Institute, Public  
Service Company  
- Certificate of Accreditation N° 479/2007  
Prosecká 412/74  
190 00 PRAHA 9  
Order no. 1 11 458/Z210110094*

Date of issue:

*2011-04-15*

Copies in total:

*4*

Copy number:

*3*

Pages in total:

*3*

## 1. INTRODUCTION

- 1.1. This Classification Report specifies the classification method for the product conformity with the procedures set forth in ČSN EN 13501-5+A1.
- 1.2. This Classification Report has 3 pages and it can be used or reproduced as a whole only.

## 2. DETAILS OF CLASSIFIED PRODUCT

### 2.1. General

*Waterproof membrane FATRAFOL 810/V, thickness of 1.5 mm* is the PVC-P roof waterproof membrane made by rolling and lamination, reinforced with a polyester grid.

### 2.2. Detail roof description

Composition from the upside:

*Waterproof membrane FATRAFOL 810/V, thickness of 1.5 mm*

glass fibre fleece - 120 g/m<sup>2</sup>

thermal insulation – EPS 150 S foam polystyrene boards, thickness of 200 mm

vapor barrier - FATRAPAR foil, thickness of 0.20 mm

underlying chipboard panel

Anchorage of *waterproof membrane FATRAFOL 810/V (thickness of 1.5 mm)*, glass fibre fleece (120 g/m<sup>2</sup>), thermal insulation from EPS 150 S foam polystyrene boards, thickness of 200 mm and vapor barrier FATRAPAR (*thickness of 0.2 mm*) into the underlying chipboard panel was carried out mechanically using the anchors placed in the overlap of the foil.

The tests were performed on the underlying boards from chipboards made according to clause 6.5.4.3 b) – it is valid for all wood coherent boards with the minimal thickness of 12 mm, all boards from wood decks with straight edges and for all non-flammable coherent boards with cracks maximum 5 mm.

The roof pitch, tested at 5°, is determined in practice according to clause 6.5.4.4.1 for a roof pitch to 10°.

## 3. TESTS REPORTS / EXTENDED APPLICATION REPORTS AND TEST RESULTS IN SUPPORT OF CLASSIFICATION

### 3.1. Test report

Name of the Laboratory Address Accreditation number:	Name of sponsor of the Test Report	Report number	Test method
PAVUS, a. s. Veselí nad Lužnicí AZL č. 1026	Fatra, a.s. tř. Tomáše Bati 1541 736 61 Napajedla	Pr-11-2.044 2011-04-15	ČSN P ENV 1187 – Test method 3

3.2. Test results of the roofs exposed to the impingement of external fire

Pitch: 5°

Substrate: underlying chipboard panel and composition according to 2.2.

Parameter	Criteria			Test Results		Conformity		
	Class B <sub>ROOF</sub> (t3)	Class C <sub>ROOF</sub> (t3)	Class D <sub>ROOF</sub> (t3)	Specimen 1	Specimen 2	Class B <sub>ROOF</sub> (t3)	Class C <sub>ROOF</sub> (t3)	Class D <sub>ROOF</sub> (t3)
Fire external propagation's time $T_E$	≥ 30 min	≥ 10 min		30 min	30 min	yes	-	-
Time till burn-through $T_p$	≥ 30 min	≥ 15 min	> 5 min	-	-	yes	-	-

4. CLASSIFICATION AND FIELD OF APPLICATION

4.1. Reference of classification

This classification has been carried out in accordance with clause 8.3 and 9, ČSN EN 13501-5 + A1.

4.2. Classification

The product – *FATRAFOL 810/V*, thickness of 1.5 mm - is, in conformity with its behaviour under the tests of the roofs exposed to the impingement of external fire, classified into the class below:

**B<sub>ROOF</sub> (t3)**

4.3. Field of application

This classification applies for the following end-use applications:

*Waterproof membrane FATRAFOL 810/V*, thickness of 1.5 mm is intended as the anchored membrane for waterproofing roof systems in a pitch to 10°. It is valid for all wood coherent boards with the minimal thickness of 12 mm, all boards from wood decks with straight edges and for all non-flammable coherent boards with cracks maximum 5 mm.

5. LIMITATIONS

This Classification Report does not represent type approval or certification of the product.

This classification is valid, if it does not occur to the changes of conditions, under which was issued.

The customer may request the issuing authority to review the influence of changes to the classification availability.

Elaborated by:



Jiří Příbyl

Fire testing laboratory

**PAVUS, a. s.**

Autorizovaná osoba AO 216  
Pobočka  
391 81 Veselí nad Lužnicí ©

Checked by:



Ing. Pavel Neudert, CSc.



Approved by:



Ing. Jaroslav Dufek

